

Williams Visit Report

School: Antioch High School

Visit Date: 8/23/17

Uniform Complaint Policies: In Compliance

SARC: sufficient

Textbooks:

Visitation:

1. ELA: sufficient
2. Math: sufficient
3. Social Studies: sufficient
4. Science: sufficient
5. ELD: sufficient
6. Foreign Language – sufficient

Document Review:

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies – sufficient
4. Science: - sufficient
5. ELD - sufficient
6. Foreign Language – sufficient

Overall Facilities Rating: GOOD 93.53 %

Grounds and facilities reflected well, except where noted. Parts of campus are under construction. Issues that impacted the report were mostly in the older 300, 400, and 500 wings, and in the portable buildings and related areas.

Facility issues which affect the overall rating:

1. Mechanical / HVAC
 - a. Portables Boys' Restroom – Exhaust inop
2. Interior Surfaces
 - a. 300 Hallway – damaged/missing ceiling tiles; door paint in disrepair (west end)
 - b. 400 Hallway – damaged/missing ceiling tiles; door paint in disrepair (west end)
 - c. 500 Hallway – damaged/missing ceiling tiles; door paint in disrepair (west end)
 - d. 303 – overhead storage

Williams Visit Report

- e. P8 – damaged blinds, unsecured cabinet
- f. Room 602 – not enough desks
- 3. Overall Cleanliness
 - a. PE Bldg. – tumbling mats/clutter
 - b. 300 Bldg. exterior – building hygiene (cobwebs, dust, debris)
 - c. 300 Bldg boys’ rest room – custodial detail
 - d. 300 Bldg girls’ rest room - custodial detail
 - e. 400 Bldg. exterior – building hygiene; paint in disrepair
 - f. 500 Bldg. exterior – building hygiene (cobwebs, dust, debris)
 - g. Portables and areas – Litter, building hygiene
 - h. Portables Boys’ Restroom – custodial detail
 - i. Portables Girls’ Restroom – custodial detail
 - j. 1100 bldg. – building hygiene (cobwebs, dust, debris)
 - k. Weight Room – unkempt, dirty concrete area IFO entry of weight room
 - l. Tennis Courts – building hygiene, unkempt
 - m. P9 – cleanliness issues
 - n. P10 – cleanliness issues
 - o. P11 – cleanliness issues
- 4. Electrical
 - a. PE Bldg. – exterior data panels unsecured
 - b. Richardson Gym – damaged junction/conduit near exit; inop lights
 - c. Richardson Gym boys’ rest room – missing light covers; inop lights
 - d. Boys’ locker room – missing light covers; inop lights
 - e. 300 Bldg. exterior – damaged/inop lights
 - f. 300 Hallway – damaged emergency light fixture; inop lights
 - g. 300 Bldg girls’ rest room - inop lights
 - h. 400 Bldg. exterior – damaged/inop lights
 - i. 400 Hallway – inop lights
 - j. 500 Bldg. exterior – damaged/inop lights
 - k. 500 Hallway – damaged emergency light fixture; inop lights
 - l. Portables and areas – damaged/inop lights
 - m. Portables Boys’ Restroom – inop lights
 - n. Portables Girls’ Restroom – inop lights
 - o. 1100 bldg. – damaged/inop lights
 - p. P3 - inop lights
 - q. P5 - inop lights
 - r. P6 - inop lights
- 5. Restrooms
 - a. Portables Boys’ Restroom – general disrepair
- 6. Sinks and Fountains
 - a. Richardson Gym – inop drinking fountain
 - b. Girls’ locker room – inop drinking fountain
- 7. Fire Safety

Williams Visit Report

- a. PE Bldg. – missing fire extinguisher
- b. Wrestling gym – missing fire extinguisher
8. Structural damage
 - a. Portables and areas – paint, siding, skirting, flashing, wood trim in disrepair; portables reflect age, wear and tear
 - b. Portables Boys' Restroom – paint in disrepair
 - c. Portables Girls' Restroom – paint in disrepair
9. Roofs
 - a. Portables and areas – damaged gutters, downspouts
10. Playgrounds / school grounds
 - a. Portables and areas – unkempt
 - b. Portables Boys' Restroom – unkempt
 - c. Tennis Courts – unkempt ground
11. Windows/doors
 - a. Richardson Gym – broken high windows
 - b. Girls' locker room – broken window in door at entry
 - c. Portables and areas – missing screens, window unkempt, ramps in disrepair
 - d. Portables Boys' Restroom – damaged windows, missing screens
 - e. P13 – window damaged, stained