

# Williams Visit Report

**School: El Dorado Middle School**

**Visit Date: 8/28/17**

**Uniform Complaint Policies: In Compliance**

**SARC: In Compliance**

**Textbooks:**

**Document Review:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. Foreign Language – sufficient

**Visitation:**

6. ELA - sufficient
7. Math: - sufficient
8. Social Studies - sufficient
9. Science: - sufficient
10. Foreign Language – sufficient

**Facility issues which affect the overall rating:**

1. Mechanical / HVAC
  - a. F2 – warm temperature
2. Interior Surfaces
  - a. D6 - unsecured whiteboard
  - b. C3 – damaged ceiling tiles IBO class; unsecured bookcase(s)
  - c. D2 – damaged built-in table LO entryway
3. Overall Cleanliness
  - a. E3 – unassembled shelving IBO class
  - b. G2 – entry missing mat(s)/ damaged/unsecured moulding
4. Electrical
  - a. C8 – exposed wire(s) from ceiling
  - b. C10 – missing light cover(s)
  - c. D5 – inop light(s)
  - d. P2 – inop light(s)

## Williams Visit Report

5. Restrooms
  - a. Girls' restroom Bldg. A – unsecured toilet seat (HC stall)
6. Fire Safety
  - a. D6 - missing fire extinguisher(s)
  - b. E3- missing fire extinguisher(s)
  - c. C5- missing fire extinguisher(s)
  - d. D2- missing fire extinguisher(s)
7. Roofs
  - a. C4 – damaged/missing roof tile(s)
  - b. C8 – damaged/missing roof tile(s)
8. Playgrounds / school grounds
  - a. C8 – missing tile IFO class
9. Windows/doors
  - a. MPR – damaged lockers

**Overall Facilities Rating: GOOD 94.96%**

**A very organized visit, even though it was unannounced. The paint on the outside of the school looks great! A very welcoming environment.**