# Williams Visit Report

### School: Oakley Elementary School

#### Visit Date: August 2, 2017

## Uniform Complaint Policies: In Compliance

#### SARC: In Compliance

#### **Textbooks:**

#### **Document Review:**

- 1. ELA sufficient
- 2. Math: sufficient
- 3. Social Studies sufficient
- 4. Science: sufficient
- 5. ELD sufficient

### Visitation:

- 1. ELA sufficient
- 2. Math: sufficient
- 3. Social Studies sufficient
- 4. Science: sufficient
- 5. ELD sufficient

#### Facility Notes:

- 1. Interior Surfaces
  - a. Room 6 Loose transition strip carpet/linoleum
  - b. Room 21 aged ceiling tiles (loose, stained or damaged in most classrooms)
  - c. Room 42 unsecured cabinet
- 2. Cleanliness
  - a. Room 1 carpet stains
- 3. Electrical
  - a. Room 6 inop lights
  - b. Room 34 cord management
- 4. Restrooms/Fountains
  - a. Boys' restroom, Wing 1 loose faucets
  - b. Girls' restroom, Wing 1 loose toilet seats
  - c. Boys' restroom, Wing 1 loose toilet seats
- 5. Structural damage
  - a. Multi-purpose room Loose paint (paint in disrepair→exterior facing playground)
  - b. Wing 1 Bldg. hallway paint in disrepair at most exterior overhangs
  - c. Wing 2 Bldg. hallway paint in disrepair at most exterior overhangs

# Williams Visit Report

- d. Wing 3 Bldg. hallway paint in disrepair at most exterior overhangs
- e. Kindergarten Bldg. wood rot at perimeter of overhang IBO rooms 12-13
- 6. Playgrounds / school grounds
  - a. Wing 1 Bldg. hallway irrigation overspray affecting cleanliness of windows
  - b. Wing 2 Bldg. hallway irrigation overspray affecting cleanliness of windows
  - c. Kindergarten play structure concerns voiced over use of wood chips instead of standard playground tanbark
  - d. General grounds benches between wings are showing signs of rusting
- 7. Doors Windows
  - a. Exit doors misaligned

# Overall Rating: GOOD 93.43%

Campus was well kept and very clean. All classrooms had materials for students and were well organized, enabling a positive learning environment.