

Williams Visit Report

School: Willow Cove Elementary School

Visit Date: 8/18/2017

Uniform Complaint Policies: In Compliance

SARC: In Compliance

Textbooks:

Document Review:

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient

Visitation:

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient

Facility Issues that affect the overall rating:

1. Mechanical / HVAC
 - a. Bldg. 1, boys' restroom – inop ventilation
2. Interior Surfaces
 - a. Admin bldg.. – overhead storage
 - b. Library – overhead storage
3. Electrical
 - a. Bldg. 1, boys' restroom – inop lights
 - b. Bldg. 2, girls' restroom – missing light covers
 - c. Upper bldg.. 5, boys' restroom – inop/missing light fixture(s)
 - d. Upper bldg.. 5, girls' restroom – inop/missing light fixture(s)
 - e. Room 3 – inop light(s)
 - f. Room 31 – missing light cover(s)
4. Playgrounds / school grounds
 - a. Grounds Main Courtyards – unkempt walkway (trip/fall hazard)

Facilities Rating: GOOD 95.07%

School is well run...strong leadership! A new wing is under construction, and the whole school is in the process of re-roofing. Overhead storage issues throughout site.