

# Williams Visit Report

**School: DeJean Middle School**

**Visit Date: 8/31/17**

**Uniform Complaint Policies: In Compliance**

**SARC: In Compliance**

**Textbooks:**

**Document Review:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient

**Visitation:**

1. ELA - sufficient
2. Math: - sufficient
3. Social Studies - sufficient
4. Science: - sufficient
5. ELD - sufficient

**Overall Facilities Rating: GOOD 92.54%**

**Grounds look great! Everyone was helpful, and we felt very welcome. Students and staff are engaged and working hard!**

**Facility issues which affect the overall rating:**

1. Interior Surfaces
  - a. Bldg. B, stairwells and hallways – damaged acoustic ceiling
  - b. Bldg. C, stairwells and hallways – damaged acoustic ceiling
  - c. Bldg. D, stairwells and hallways – damaged acoustic ceiling
  - d. B103 – unsecured bookcase(s)
  - e. B203 – damaged ceiling tile(s)
  - f. C203 – damaged ceiling tile(s)
  - g. D104– missing ceiling tile(s)
  - h. D202 – unsecured shelving
  - i. D204 – unsecured shelving
2. Electrical
  - a. Cafeteria – damaged electrical cover on the floor
  - b. D202 – inop lights

# Williams Visit Report

3. Restrooms
  - a. Bldg. D, girls' restroom – damaged toilet(s)
  - b. Boys' locker room – damaged toilet(s)
  - c. Girls' locker room – damaged toilet(s)
  - d. Cafeteria, girls' restroom – damaged toilet(s)
  - e. Bldg. E, boys' restroom – damaged toilet(s)
4. Sinks and Fountains
  - a. Bldg. D, stairwells and hallways – inop water fountain(s)
  - b. Boys' locker room – inop faucet(s)
  - c. C106 - inop faucet(s)
5. Fire Safety
  - a. C202 – missing or damaged safety blanket (s)